



INSTITUT IGH, d.d.
 Laboratorij za građevinsku fiziku
 Building Physics Laboratory
 Janka Rakuše 1, 10000 ZAGREB, CROATIA
 Tel: +385 1/6125 111, Fax: +385 1/6125 100
 www.igh.hr



Report number: 72570/032/21-155/21 (EN excerpt)

ODS3 032/2021

**Excerpt from the REPORT ON TESTING AND ASSESSMENT OF THE
 CONSTANCY OF PERFORMANCE ON THE BASIS OF TEST NO.
 72570/032/21-155/21**

(based on sampling carried out by the manufacturer)

Building product:	Single casement, tilt and turn window made of PVC profiles, system Baufens 8500 PLATNUM, glazed with triple IZO glass pane, thickness 36 mm (4 mm float glass + 12 mm argon + 4 mm float glass + 12 mm argon + 4 mm ClimaGuard glass). Overall frame width/height: 1,23 m x 1,48 m.
Manufactured by:	YAVUZ COMPANY d.o.o., Čehaje bb, BiH-75350 Srebrenik.

Is classified according to the below given standards:

HRN EN 12207:2017 Windows and Doors – Air permeability – Classification (EN 12207:2016)	4
HRN EN 12208:2001 Windows and Doors – Watertightness – Classification (EN 12208:1999)	7A
HRN EN 12210:2016 Windows and Doors – Resistance to wind load - Classification (EN 12210:2016)	C5
HRN EN ISO 717-1:2021 Acoustics – Rating of sound insulation in buildings and of building elements – Part 1: Airborne sound insulation (ISO 717-1:2020; EN ISO 717-1:2020)	$R_w(C,C_{tr}) = 34 (-2,-6)$ dB
HRN EN 10077-1:2017 Thermal performance of windows, doors and shutters – Calculation of thermal transmittance -- Part 1: General (ISO 10077-1:2017, Corrected version 2020-02; EN ISO 10077-1:2017)	$U_n = 1,0$ W/(m ² K)

Report number: 72570/032/21-155/21

Date: 20 August 2021

Testing laboratory: Institut IGH d.d., Zagreb

Signature:

